

Data quality issues for synchrophasor applications Part II: problem formulation and potential solutions

Can HUANG¹, Fangxing LI¹ , Lingwei ZHAN¹, Yao XU¹,
Qinran HU¹, Dao ZHOU¹, Yilu LIU¹



Abstract This work investigates the data quality issue for synchrophasor applications, and pays particular attention to synchronization signal loss and synchrophasor data loss events. First, the historical synchronization signal loss events are analyzed and the potential reasons and solutions are discussed. Then, the scenario of a small amount of synchrophasor data loss is studied and a Lagrange interpolating polynomial method is used to adaptively estimate the incomplete and missing data. The performance of proposed method is demonstrated with simulation results. Specifically, the proposed method considers the trade-off between the estimation accuracy and the hardware cost, and could be efficiently employed in reality.

Keywords GPS loss, Synchronization signal loss, Synchrophasor data loss, Estimation, Forecasting

1 Introduction

In the past decade, an increasing number of synchrophasor systems have been employed around the world, and a variety of synchrophasor applications have been implemented in power grids [1]. These synchrophasor systems and applications make use of advanced information and communication technologies (ICTs), such as the global positioning system (GPS), phasor measurement unit (PMU), phasor data concentrator (PDC), and high-speed dedicated communications as shown in Fig. 1, with the aim of enabling wide-area monitoring, protection and control and enhancing the overall performance of power grids. To realize these great potentials, efficient measurement and communication systems are demanded [1–6].

However, the actual measurement and communication systems inevitably involve data quality issues. For instance, a measurement device may cause a data accuracy issue because of device errors or timing signal loss [7], and a communication link may induce data loss and latency issues due to unintentional reasons (e.g., equipment malfunctions and communication infrastructure limits) or intentional cyber-attacks [8, 9]. These data quality issues may impact or even disable certain application functionalities. Consequently, a great deal of research effort in academia and industry has been devoted to addressing the data quality issue, especially the data accuracy, latency, and loss issues.

First, the data accuracy issue primarily derives from measurement equipment and devices, such as instrument transformers and PMUs. Conventional instrument

CrossCheck date: 12 June 2016

Received: 24 January 2016 / Accepted: 12 June 2016 / Published online: 18 July 2016

© The Author(s) 2016. This article is published with open access at Springerlink.com

✉ Fangxing LI
fli6@utk.edu

Can HUANG
chuang16@vols.utk.edu

Lingwei ZHAN
lzhane@vols.utk.edu

Yao XU
yxu4@lamar.edu

Qinran HU
qinranhu@g.harvard.edu

Dao ZHOU
dao@vols.utk.edu

Yilu LIU
liu@utk.edu

¹ Department of Electrical Engineering and Computer Science,
The University of Tennessee, Knoxville, TN 37996, USA






Fig. 1 A typical synchrophasor system

transformers have inherent limitations on high-voltage measurement and isolation; while classic PMUs using discrete-Fourier-transform algorithms have a low computational burden but their accuracy degrades in the presence of frequency offsets and dynamic conditions. Accordingly, advanced instrument transformers like electronic instrument transformers [10, 11] and alternative PMUs using sophisticated measurement algorithms [12–14] have been developed. Those approaches greatly improve the synchrophasor measurement accuracy under both steady-state and dynamic conditions.

Second, for the data latency, the previous researches primarily focus on three aspects 1) modeling the communication delay in theoretical and statistical perspectives, such as constant modeling, stochastic modeling, and bounded modeling [8, 15], 2) developing special protection schemes and control strategies with the consideration of latencies [15–19], and 3) optimizing the communication infrastructure, like communication architecture, medium, and protocols, and restricting the communication delay to an acceptable range [20–25]. Those design and approaches have been selectively used in wide-area protection & control and other advanced applications.

Further, for the data incompleteness and missing, numerous researches work on reducing the risk of data loss, such as the ones enhancing communication performance in terms of communication architecture, bandwidth, and redundancy [21–27]. In addition, some researches deal with the data loss issue in a positive way. For example, a predictive control strategy for wide-area damping control was presented in [28] with the consideration of data loss and other physical constraints, and a data reconstruction method using the low-rank matrix completion approach was provided in [29], in which way the lost data could be partially recovered at a control center.

This work studies the data quality issue for synchrophasor applications. In Part I, the data quality issue is reviewed in a comprehensive way and in Part II the potential reasons and solutions for the data quality issue are investigated. Specifically, Part II pays particular attention to synchronization signal loss and synchrophasor data loss events. For the former, the historical timing signal loss events are analyzed and the potential reasons and solutions are discussed. For the latter, the synchrophasor data loss,

especially the scenario of a small amount of synchrophasor data loss, is studied, and the possible estimation methods like substitution, interpolation, and forecasting methods are examined. The estimation methods can improve the accuracy and availability of synchrophasor measurements, and mitigate the effect of data loss on synchrophasor applications.

2 Synchronization signal loss

Accurate and reliable synchronization signals play a critical role in synchrophasor systems. They provide the common timing reference for data measurement and synchronization, and largely determine the accuracy and availability of synchrophasor data. However, according to the statistics in Part I, a large number of PMUs and FDRs experienced timing signal loss (i.e. GPS signal loss). The potential reasons and solutions are explored in this section.

2.1 Potential reasons

Theoretically, the GPS signal availability, especially the strength, might be affected by two factors: the weather and the surrounding of GPS antennas.

The weather events primarily refer to the ionospheric scintillation and solar radio burst, which can degrade GPS signal performances [30]. In particular, the strongest scintillation normally occurs at the equatorial regions. This means more interference signals will be applied to the GPS antenna located in the low latitude [31].

In order to investigate the impact of weather events on GPS signal loss, two studies are performed. First, the average yearly GPS-signal-loss events of the FDR from 2010 to 2012 are counted. As shown in Fig. 2, the GPS-signal-loss events of all FDRs across North America are depicted in the spatial manner, while no clear geological




Fig. 2 Spatial distribution of GPS signal loss in North America

pattern is identified from the historical data. Second, the average monthly GPS-signal-loss events of the FDR from 2010 to 2012 are calculated as shown in Fig. 3, and the historical solar activities from 2010 to 2012 are reviewed (it is reported that the largest solar activity happened on March 7, 2012 00:24 UTC - the sun unleashed an X5.4-class solar flare) [32]. By comparing the trend in Fig. 3 and the trend in reference [32], no obvious relationship between GPS signal loss and solar radio bursts is found. These two studies imply that the overall GPS signal availability is not significantly affected by the weather.

In addition, the GPS signal availability is also affected by the surrounding of GPS antennas [33]. For example, an FDR is usually installed indoor with a directional GPS antenna instead of an omnidirectional GPS antenna. The performance of the antenna or antenna reception may be affected by the surrounding. For instance, whether the antenna is installed near a window with an open view to the sky, and whether the antenna reception is located nearby the buildings or obstacle that frequently reflect or block GPS signals.

2.2 Potential solutions

To improve the accuracy and availability of GPS signals, the performance of GPS receivers should be considered first. For instance, if a PMU uses an on board GPS receiver, the PMU can parse the GPS signal strength information, e.g., the number of locked satellites from a GPS receiver, and further track the GPS signal strength; and if a PMU uses GPS signals as synchronization signals, the GPS signal strength can be enhanced through installing omnidirectional antenna on the roof with the open sky.

Note that the antenna type will impact the GPS signal availability. Directional antennas transmit and receive signals in a particular direction, so they are generally subject to a particular reception pattern (e.g., they would lower the signal availability when the directional path is affected). In contrast, omnidirectional antennas transmit




Fig. 3 Temporal distribution of GPS signal loss from 2010 to 2012

and receive signals in all horizontal directions, enabling users to use the GPS antenna without concerning the antenna's reception pattern. Therefore, omnidirectional antennas can improve reception in such terrains where directional path would be affected.

Some emerging data analytics solutions can also improve the timing accuracy of synchrophasor measurements. For the lost or drifted timing signals, the context data in the time range with available and accurate timing, or the data from other units, can help reconstruct the missing information. Data interpolation and data realignment tools also provide the possibility to patch the timestamp or shift the data back to its correct position [34].

Moreover, since the availability of GPS signals is difficult to be guaranteed, some backup synchronized timing sources can be used, such as network time protocol (NTP), e-Loran, and chip scale atomic clock (CSAC). Several backup synchronized timing technologies have been employed for synchrophasor measurement. It is demonstrated that they provide ultra-high timing accuracy and reliability to meet IEEE Standards [7], [35–37].

3 Synchrophasor data loss

As discussed in Part I, a number of synchrophasor applications (e.g., Class-A applications) prefer accurate and complete synchrophasor data. The data loss issue may lower and even disable the performances of certain synchrophasor applications [4]. The incomplete or missing data can make the power grid unobservable and vulnerable, and even aggravate the cascading effects in large-scale blackouts [28], [38]. PMU Application Requirements Task Force at North American Synchrophasor Initiative (NASPI) has been working on standardizing and quantifying the requirements of synchrophasor applications [39].

To address the data loss issue, several advanced data recovery techniques were proposed in the literature [25, 29]. Those data recovery techniques are applicable for off-line applications but indeed costly for the majority of real-time applications. Moreover, as discovered in Part I, about 95% data loss events involve only one to three lost packages and a large amount of data loss is a small probability event. Hence, this paper focuses on the scenario of a small amount of package losses, and examines a set of estimation methods to mitigate the corrupted and missing data, including substitution, interpolation, and prediction.

3.1 Lagrange interpolating polynomial method

Currently, there is no standardized method to address the issue of synchrophasor data loss. Most commercial

PDCs use the substitution method, in which the lost data are simply set to zero. Obviously, this method will lower the data accuracy and completeness. One alternative method is interpolation, and a Lagrange interpolating polynomial method is presented below [40].

In general, the Lagrange polynomial $L(x)$ passes through a set of given data points $(x_1, y_1) = f(x_1)$, $(x_2, y_2) = f(x_2)$, ..., $(x_n, y_n) = f(x_n)$, and other points can be approximately calculated with

$$L(x) = \sum_{j=1}^n y_j \cdot \ell_j(x) = \sum_{j=1}^n y_j \cdot \prod_{\substack{k=1 \\ k \neq j}}^n \frac{x - x_k}{x_j - x_k} \quad (1)$$

where $\ell_j(x)$ is the coefficient in the Lagrange polynomial.

Considering the trade-off between algorithm accuracy and hardware-cost, n is selected as 3 and (1) can be rewritten as the quadratic interpolation in (2).

$$L(x) = y_1 \frac{(x - x_2)(x - x_3)}{(x_1 - x_2)(x_1 - x_3)} + y_2 \frac{(x - x_1)(x - x_3)}{(x_2 - x_1)(x_2 - x_3)} + y_3 \frac{(x - x_1)(x - x_2)}{(x_3 - x_1)(x_3 - x_2)} \quad (2)$$

The first case assumes only one synchrophasor package is lost. The simple lost data can be estimated with the quadratic interpolation in (2). Also, since only three points are required in the estimation, the lost data can be further estimated with the weighted interpolation. For instance, the lost point v_4 as shown in Fig. 4a can be calculated with (2) in the following ways

$$\hat{v}_4|_{1,2,3} = v_1 - 3v_2 + 3v_3 \quad (3)$$

$$\hat{v}_4|_{2,3,5} = -\frac{1}{3}v_2 + v_3 + \frac{1}{3}v_5 \quad (4)$$

$$\hat{v}_4|_{3,5,6} = \frac{1}{3}v_3 + v_5 - \frac{1}{3}v_6 \quad (5)$$




Fig. 4 Synchrophasor data loss with different conditions

$$\hat{v}_4|_{5,6,7} = 3v_5 - 3v_6 + v_7 \quad (6)$$

$$\hat{v}_4 = c_1 \hat{v}_4|_{1,2,3} + c_2 \hat{v}_4|_{2,3,5} + c_3 \hat{v}_4|_{3,5,6} + c_4 \hat{v}_4|_{5,6,7} \quad (7)$$

where c_1 , c_2 , c_3 and c_4 are the coefficients in the weighted interpolation. The average weights are used here since their practicality and simplicity.

The special condition as depicted in Fig. 4b is considered, in which the first or last package in a dataset is lost. In this case, the estimates can be calculated with the polynomial extrapolation in (8) and (9), respectively.

$$\hat{v}_1 = 3v_2 - 3v_3 + v_4 \quad (8)$$

$$\hat{v}_7 = v_4 - 3v_5 + 3v_6 \quad (9)$$

The second case considers the continuous package loss and the lost data can be estimated with the extrapolation as well. For instance, the three points as shown in Fig. 4c are lost and they can be recursively estimated as follows

$$\hat{v}_4 = v_1 - 3v_2 + 3v_3 \quad (10)$$

$$\hat{v}_5 = v_2 - 3v_3 + 3\hat{v}_4 \quad (11)$$

$$\hat{v}_6 = v_3 - 3\hat{v}_4 + 3\hat{v}_5 \quad (12)$$

Note that the extrapolation assumes the data are smooth and performs poorly for the dramatically changing data. Also, a maximum package loss amount is normally preset in power system engineering, and an alarm will arise when the actual package loss number exceeds the maximum amount.

In addition, the practical synchrophasor package may be lost discontinuously and randomly, and they can be compensated with the interpolation and extrapolation collectively. A simple example is presented in Fig. 4d and the discontinuous points can be calculated as follows

$$\hat{v}_3 = \frac{1}{3}v_2 + v_4 - \frac{1}{3}v_5 \quad (13)$$

$$\hat{v}_6 = \hat{v}_3 - 3v_4 + 3v_5 \quad (14)$$

$$\hat{v}_7 = v_4 - 3v_5 + 3\hat{v}_6 \quad (15)$$

Here, the 3rd point in Fig. 4d can be further estimated with the weighted interpolation, in which the estimation accuracy is expected to improve. Also, the estimation errors in above estimations are unavoidable and can be expressed as

$$E(x) = f(x) - L(x) = \frac{f^{(n)}(\xi)}{3!} \cdot \prod_{k=1}^3 (x - x_k) \quad (16)$$

Further, for the current and voltage with harmonics as $v_k = v_0 + \sum_{h=1}^{\infty} v_h \sin(h\omega t + \varphi_h)$ the related estimation error can be written as

$$E(t) \leq \frac{\omega^3}{3!} \sum_{h=1}^{\infty} (v_h h^3) \left| \prod_{j=1}^3 (t - t_j) \right| \quad (17)$$

Typically, for the rate of change of frequency (ROCOF) or frequency measurement, its accuracy is evaluated with absolute errors (e.g., frequency error Hz or ROCOF error Hz/s), while for the phasor measurement, its accuracy is evaluated with the total vector error (TVE) as

$$TVE(n) = \sqrt{\frac{(\hat{X}_r(n) - X_r(n))^2 + (\hat{X}_i(n) - X_i(n))^2}{(X_r(n))^2 + (X_i(n))^2}} \quad (18)$$

where $X_r(n)$ and $X_i(n)$ are the sequences of theoretical values of the input signal at the instant of time (n), and $\hat{X}_r(n)$ and $\hat{X}_i(n)$ are the sequences of estimates. The TVE of P class and M class PMUs is required to be less than 1% in steady-state in IEEE Standard C37.118.

3.2 Forecasting method

In addition to the substitution and interpolation, the prediction is also widely used in data estimation [41, 42]. Here, the synchrophasor data are viewed as an observed time series driven by a stochastic process and represented by a state equation and a measurement equation as follows:

$$x_{k+1} = A_k x_k + B_k \omega_k \quad (19)$$

$$y_k = C_k x_k + D_k v_k \quad (20)$$

where x_{k+1} is the state that characterizes the measurement y_k ; it is a variable of the time series determined by the previous state x_k and the noise term ω_k introduced at each k . A_k , B_k , C_k and D_k denote the corresponding coefficients.

The unknown system parameters $\theta_k = \{A_k, B_k, C_k, D_k\}$ and states $\{x_k\}$ can be estimated through a finite set of received signal measurement data $\{y_1, y_2, \dots\}$. Also, the parameters in (19) and (20) are estimated using the prediction error minimization (PEM) algorithm here, with the objective of minimizing prediction errors. The PEM updates the measurement set every time when the new measurement comes in, such that the whole model is updated with the new measurement set to keep up with time-varying parameters [42]. The PEM algorithm estimates the system parameters by minimizing a least square cost function as follows:

$$\min J_N = \min \frac{1}{N} \sum_{k=0}^{N-1} \|y_k - \hat{y}_k\|_2^2 \quad (21)$$

When the lost synchrophasor data are treated as the synchrophasor data in future, they can be recursively predicted on the basis of the previous states and estimated parameters. In particular, the PEM algorithm employs a

finite number of stored measurements for the next prediction where the store size can be chosen as small as the algorithm has a solution. Thus, different from the widely used artificial neural networks based prediction approaches which require large historical data for data modeling and training [43], the presented prediction method results in acceptable hardware cost and it is applicable for the data estimation of on-line applications [4, 9, 39].

4 Simulation results

In order to demonstrate the performance of the proposed methods, the simulation with MATLAB is performed here. Because the power system data may vary regularly in normal operation but dramatically change in a fault or disturbance, the real PMU data in a fault event are used as inputs as shown in Fig. 5. Because of the limited space, three groups of twenty samples are selected from the pre-fault, in-fault, and post-fault states in Fig. 5 and further used as the test data as shown in Fig. 6.

4.1 Substitution and interpolation based estimation

The substitution and the interpolation based estimation methods are tested. First, three sets of twenty samples in Fig. 6 representing the different conditions in power grids are used as test inputs. Then, the 5th, (5th, 6th), (5th, 6th, 7th), ..., (5th, ..., 14th) samples are manually set lost, and the proposed weighted interpolation method with different times of estimation (e.g., two times and three times of estimation) is applied to estimate the lost data. The corresponding simulation results are presented in Fig. 7.

Note that this paper focuses on the scenario of a small amount of synchrophasor data loss and the simulation studies the scenario of one to ten continuous package losses. The twenty samples are good enough for the maximum continuous package losses.

For the substitution, the lost sample is treated as “zero” and its TVE sharply increases to 100%. Hence, the




Fig. 5 PMU data profile in one minute




Fig. 6 Test data in diverse conditions




Fig. 7 Simulation results of the weighted interpolation method

continuous data loss will lower the accuracy of synchrophasor data and even lead to the malfunction of certain synchrophasor applications [4].

For the interpolation, it is observed that in the pre-fault and post-fault states, the lost data can be efficiently estimated ($TVE < 1\%$), whereas in the faulty state, the estimation error is acceptable only in the scenario of one or two continuous package losses.

Moreover, the estimation accuracy is improved by the weighted interpolation, e.g., the three times estimation generally presents lower TVE than the one time estimation. The estimation accuracy is also affected by the nature of synchrophasor data, e.g., the TVE of the scenario of nine continuous data loss in Fig. 7b suddenly drops to 1% since the data changes gently in this field. Therefore, the proposed interpolation method can adaptively estimate the missing data in different conditions, and the estimation results are acceptable in the scenario of the small amount of data loss.

Further, the proposed Lagrange interpolating polynomial algorithm only includes simple addition and multiplication as shown in (2)–(15), which can be embedded in a lookup table. Thus, the proposed interpolation method can be efficiently employed in a PDC in practice.

4.2 Prediction based estimation

The prediction method with the same inputs in Fig. 6b, c is tested as well. It is observed from the simulation results in Figs. 8 and 9 that the prediction method can estimate the lost data with high accuracy, while a bit high prediction error still exists in the scenario of continuous data loss and/or dynamic data changes.

For example, for the voltage angle values in Fig. 8b, d, the high prediction accuracy is obtained for the voltage angle varying in a small range whereas the high prediction errors happen to certain voltage angles dynamically changing.




Fig. 8 Simulation results of the prediction method




Fig. 9 TVE results of the prediction method

Table 1 Brief review of the three estimation methods

Estimation method	Substitution	Interpolation	Prediction
Accuracy	Low	High	High
Speed	Ultra-fast	Very-fast	Fast
Complexity	Low	Medium	High

According to the above analysis, a brief review of the three estimation methods is provided in Table 1. The interpolation method presents comparable estimation accuracy as the prediction method but requires less hardware cost. Therefore, the interpolation method achieves the trade-off between accuracy and complexity. It is favorable for the estimation of the corrupted and missing synchrophasor data.

5 Conclusions

A number of synchrophasor applications prefer accurate, complete, and timely data, and their performances may be impacted or even disabled due to data quality issues. This paper investigates the data quality issue for synchrophasor applications and pays particular attention to the synchronization signal loss and synchrophasor data loss events.

First, the historical synchronization signal loss events are analyzed, and the potential reasons and solutions are discussed. It is found that a large number of PMUs and FDRs experienced GPS signal loss, and this issue might get worse under the bad weather and surrounding. It is advantageous to optimize the location of GPS antennas and deploy advanced ICTs and backup schemes.

Second, the issue of synchrophasor data missing and incomplete is studied. For the off-line applications, the missing data can be processed in the control center with advanced information recovery techniques; while for the real-time applications, the incomplete data normally are directly delivered to the applications, which is unfavorable for certain applications.

Further, it is observed from the statistics in Part I that about 95% data loss events involve only one to three lost packages. Hence, this paper focuses on the scenario of a small amount of synchrophasor data loss and proposes the estimation method with Lagrange interpolating polynomial algorithms. Compared with the substitution and the prediction methods, the interpolation method can estimate the lost data in diverse conditions adaptively and achieve the trade-off between accuracy and complexity. Moreover, the interpolation method requires simple calculations only, and thus can be embedded in a lookup table and employed efficiently in a practical PDC.

Future works may include the optimization of the interpolation method (e.g., the coefficients) and the implementation of the data estimation method in real PDCs.

Acknowledgment This work was supported in part by the U.S. National Science Foundation (U.S. NSF) through the U.S. NSF/Department of Energy (DOE) Engineering Research Center Program under Award EEC-1041877 for CURENT. The authors would also like to thank the editors and reviewers for their insightful comments and suggestions on improving the quality of this work.

Open Access This article is distributed under the terms of the Creative Commons Attribution 4.0 International License (<http://creativecommons.org/licenses/by/4.0/>), which permits unrestricted use, distribution, and reproduction in any medium, provided you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons license, and indicate if changes were made.

References

- Terzija V, Valerde G, Cai DY et al (2011) Wide-area monitoring, protection, and control of future electric power networks. *Proc IEEE* 99(1):80–93
- Yu XH, Xue YS (2016) Smart grids: a cyber-physical systems perspective. *Proc IEEE* 104(5):1058–1070
- Xue YS (2015) Energy internet or comprehensive energy network? *J Mod Power Syst Clean Energ* 3(3):297–301
- Huang C, Li F, Zhou D et al (2016) Data quality issues for synchrophasor applications—Part I: a review. *J Mod Power Syst Clean Energ* 4(3). doi:10.1007/s40565-016-0217-4
- Liu Y, Zhan LW, Zhang Y et al (2016) Wide-area-measurement system development at the distribution level: an FNET/GridEye example. *IEEE Trans Power Del* 31(2):721–731
- Zhou D, Guo JH, Zhang Y et al (2016) Distributed data analytics platform for wide-area synchrophasor measurement systems. *IEEE Trans Smart Grid*. doi:10.1109/TSG.2016.2528895
- Yao WX, Liu Y, Zhou D (2016) Impact of GPS signal loss and its mitigation in power system synchronized measurement devices. *IEEE Trans Smart Grid*. doi:10.1109/TSG.2016.2580002
- Huang C, Li FX, Ding T et al (2016) A bounded model of the communication delay for system integrity protection systems. *IEEE Trans Power Del*. doi:10.1109/TPWRD.2016.2528281
- Gu CJ, Jirutitijaroen P (2013) Impacts of communication failure on power system operations. In: *Proceedings of the 2013 IEEE PES Asia-Pacific power and energy engineering conference*, Hong Kong, China, 8–11 Dec 2013, 5 pp
- Huang C, Zheng JY, Su L et al (2010) Configuration of electronic transformers. *Electr Power Automat Equip* 30(3):137–140
- Zhu C, Huang C, Mei J et al (2011) Design of smart merging unit based on FPGA and ARM. *Power Syst Technol* 35(6):10–14
- Zhan L, Zhou D, King T et al (2014) Improvement of timing reliability and data transfer security of synchrophasor measurements. In: *Proceedings of the 2014 IEEE PES T & D conference and exposition*, Chicago, IL, USA, 14–17 Apr 2014, 5 pp
- Kamwa I, Samantaray SR, Joos G (2014) Wide frequency range adaptive phasor and frequency PMU algorithms. *IEEE Trans Smart Grid* 5(2):569–579
- Zhan LW, Liu Y, Culliss J et al (2015) Dynamic single-phase synchronized phase and frequency estimation at the distribution level. *IEEE Trans Smart Grid* 6(4):2013–2022
- Zhang F, Sun Y, Cheng L et al (2015) Measurement and modeling of delays in wide-area closed-loop control systems. *IEEE Trans Power Syst* 30(5):2426–2433
- Huang C, Xiao CF, Fang Y et al (2011) A method to deal with packet transfer delay of sampled value in smart substation. *Power Syst Technol* 35(1):5–10
- Anh NT, Vanfretti L, Driesen J et al (2015) A quantitative method to determine ICT delay requirements for wide-area power system damping controllers. *IEEE Trans Power Syst* 30(4):2023–2030
- Bai FF, Liu Y, Liu YL et al (2015) Measurement-based correlation approach for power system dynamic response estimation. *IET Gener Transm Distrib* 9(12):1474–1484
- Sun YH, Li N, Zhao XM et al (2016) Robust H_{∞} load frequency control of delayed multi-area power system with stochastic disturbances. *Neurocomputing* 193:58–67
- Zhu C, Huang C, Zheng JY et al (2011) Real-time measurement of communication subsystem of intelligent electronic device. In: *Proceedings of the 2011 international conference on electric information and control engineering (ICEICE'11)*, Wuhan, China, 15–17 Apr 2011, pp 626–629
- Zhu K, Chenine M, Nordström L (2011) ICT architecture impact on wide area monitoring and control systems' reliability. *IEEE Trans Power Del* 26(4):2801–2808
- Kansal P, Bose A (2012) Bandwidth and latency requirements for smart transmission grid applications. *IEEE Trans Smart Grid* 3(3):1344–1352
- Wang Y, Li WY, Lu JP (2010) Reliability analysis of wide-area measurement system. *IEEE Trans Power Del* 25(3):1483–1491
- Zhu K, Nordström L (2014) Design of wide-area damping systems based on the capabilities of the supporting information communication technology infrastructure. *IET Gener Transm Distrib* 8(4):640–650
- Duan DL, Yang LQ, Scharf LL (2011) Phasor state estimation from PMU measurements with bad data. In: *Proceedings of the 4th IEEE international workshop on computational advances in multi-sensor adaptive processing (CAMSAP'11)*, San Juan, Puerto Rico, 13–16 Dec 2011, pp 121–124
- Yu WJ, Xue YS, Luo JB et al (2016) An UHV grid security and stability defense system: considering the risk of power system communication. *IEEE Trans Smart Grid* 7(1):491–500
- Xue YS, Ni M, Yu J et al (2015) Study of the impact of communication failures on power system. In: *Proceedings of the 2015 Power and Energy Society general meeting*, Denver, CO, USA, 26–30 Jul 2015, 5 pp
- Zhang S, Vittal V (2013) Design of wide-area power system damping controllers resilient to communication failures. *IEEE Trans Power Syst* 28(4):4292–4300
- Gao PZ, Wang M, Ghiocel SG et al (2016) Missing data recovery by exploiting low-dimensionality in power system synchrophasor measurements. *IEEE Trans Power Syst* 31(2):1006–1013
- NOAA (2016) Space weather and GPS systems. National Oceanic and Atmospheric Administration (NOAA), Boulder, CO, USA
- Jiao Y, Morton YT, Taylor S et al (2013) Characterization of high-latitude ionospheric scintillation of GPS signals. *Radio Sci* 48(6):698–708
- NOAA (2016) Solar cycle progression. National Oceanic and Atmospheric Administration (NOAA), Boulder, CO, USA
- Zhao YL (2002) Standardization of mobile phone positioning for 3G systems. *IEEE Commun Mag* 40(7):108–116
- Zhao JC, Zhan LW, Liu YL et al (2015) Measurement accuracy limitation analysis on synchrophasors. In: *Proceedings of the 2015 IEEE power and energy society general meeting*, Denver, CO, USA, 26–30 Jul 2015, 5 pp

- [35] Zhao JC, Wu HW, Gu SH (2012) Digital filter design for CPT atomic clocks and FPGA realization. *J Conver Inform Technol* 7(4):97–105
- [36] Zhan LW, Liu Y, Yao WX et al (2016) Utilization of chip scale atomic clock for synchrophasor measurements. *IEEE Trans Power Del.* doi:[10.1109/TPWRD.2016.2521318](https://doi.org/10.1109/TPWRD.2016.2521318)
- [37] Lu HY, Zhan LW, Liu YL et al (2016) A microgrid monitoring system over mobile platforms. *IEEE Trans Smart Grid.* doi:[10.1109/TSG.2015.2510974](https://doi.org/10.1109/TSG.2015.2510974)
- [38] Ding T, Sun K, Huang C et al (2016) Mixed-integer linear programming-based splitting strategies for power system islanding operation considering network connectivity. *IEEE Syst J.* doi:[10.1109/JSYST.2015.2493880](https://doi.org/10.1109/JSYST.2015.2493880)
- [39] Methodology for examining the impact of error and weaknesses in PMU data on operational applications. NASPI-2016-TR-002, PNNL-25262, North American SynchroPhasor Initiative (NASPI) PMU Application Requirements Task Force (PARTF), 2016
- [40] Zhang ZD, Huang XQ, He J et al (2013) Self-adaption packet-loss-based sampled value estimation algorithm and its error analysis. *Autom Electr Power Syst* 37(4):85–91
- [41] Fan LL, Wehbe Y (2013) Extended Kalman filtering based real-time dynamic state and parameter estimation using PMU data. *Electr Power Syst Res* 103:168–177
- [42] Dong J, Ma X, Djouadi SM et al (2014) Frequency prediction of power systems in FNET based on state-space approach and uncertain basis functions. *IEEE Trans Power Syst* 29(6):2602–2612
- [43] Guo JH, You S, Huang C et al (2016) An ensemble photovoltaic power forecasting model through statistical learning of historical weather and solar irradiation dataset. In: *Proceedings of the 2016 IEEE power and energy society general meeting*, Boston, MA, USA, 17–21 Jul 2016, 5 pp

Can HUANG received the B.S.E.E. degree from Hohai University, Nanjing, China, in 2008, and the M.S.E.E. degree from Southeast University, Nanjing, China, in 2011. From 2011 to 2012, he was with the State Grid Electric Power Research Institute (NARI Group Corporation), Nanjing, China. Now he is a Ph.D. candidate in electrical engineering at the University of Tennessee, Knoxville, TN, USA. His current research interests include renewable energy integration, power system operation and control, and IT applications in power systems and power electronics.

Fangxing LI received the B.S.E.E. and M.S.E.E. degrees from Southeast University, Nanjing, China, in 1994 and 1997, respectively, and the Ph.D. degree in electrical engineering from Virginia Polytechnic Institute and State University, Blacksburg, VA, USA, in 2001. From 2001 to 2005, he was with ABB Electric Systems Consulting, Raleigh, NC, USA. He is currently a Professor in electrical engineering at the University of Tennessee, Knoxville, TN,

USA. He is an IET Fellow and a Registered Professional Engineer in the State of North Carolina. His current research interests include renewable energy integration, distributed energy resources, power markets, and smart grid.

Lingwei ZHAN received the B.S. and M.S. degrees in electrical engineering from Tongji University in 2008 and 2011, respectively, and the Ph.D. degree in electrical engineering from the University of Tennessee, Knoxville, TN, USA, in 2015. He is currently with General Electric Grid Solutions, Philadelphia, PA, USA. His current research interests include synchrophasor measurement, synchrophasor applications, embedded system design, FACTS, and HVDC.

Yao XU received the B.S. and M.S. degrees in electrical engineering from Changsha University of Science and Technology, Changsha, China, in 2006 and 2009, respectively, and the Ph.D. degree in electrical engineering from the University of Tennessee, Knoxville, TN, USA, in 2014. She is currently a visiting assistant professor at Lamar University, Beaumont, TX, USA. Her current research interests include renewable energy integration, power system control, power markets, and utility application of power electronics.

Qinran HU received the B.S. degree in electrical engineering from Southeast University, Nanjing, China, in 2010, and the M.S. and Ph.D. degrees in electrical engineering from the University of Tennessee, Knoxville, TN, USA, in 2013 and 2015, respectively. He is currently a postdoc at Harvard University, Cambridge, MA, USA. His current research interests include mechanism design, human behavior analysis, and energy market.

Dao ZHOU received the B.S.E.E. degree from North China Electric Power University, Beijing, China, in 2007, and the M.S.E.E. degree from Virginia Polytechnic Institute and State University, Blacksburg, VA, USA, in 2010. Now he is a Ph.D. candidate in electrical engineering at the University of Tennessee, Knoxville, TN, USA. His current research interests include synchrophasor applications and power system data analytics.

Yilu LIU received the B.S. degree from Xi'an Jiaotong University, Xi'an, China, in 1982, and the M.S. and Ph.D. degrees from Ohio State University, Columbus, OH, USA, in 1986 and 1989, respectively. She is currently the Governor's Chair with the University of Tennessee-Knoxville (UTK), TN, USA, and Oak Ridge National Laboratory (ORNL), Oak Ridge, TN, USA. She leads the effort to establish a nationwide power frequency dynamic monitoring network (FNET), which is now operated at UTK and ORNL as GridEye (fnetpublic.utk.edu). She is a Member of the National Academy of Engineering. Her current research interests include power system wide-area monitoring and control, large-scale power system simulation, electromagnetic transient analysis, and power transformer modeling and diagnosis.

